



United States Department of State

Washington, D.C. 20520

ATG Access, Ltd.  
Automation House  
Lowton Business Park  
Newton Road, Lowton St. Mary's  
Warrington, WA3 2AP

JUN 9 2008

Attention: Mr. Robert Ball

Dear Mr. Ball,

Based on a request from your company, a technical representative of the Department of State (DOS) recently reviewed the vehicle crash test data from a DOS approved test facility. Upon review of the crash test data provided by the test facility it has been determined that your company's anti-ram vehicle barrier meets the DOS certification standards for vehicle barriers. This testing and analysis was conducted under the current provisions of SD-STD-02.01, Revision A, *Test Method for Vehicle Crash Testing of Perimeter Barriers and Gates*, dated March 2003.

Company/Manufacturer:	ATG Access, Ltd.
Test Date:	March 26, 2008
Test Facility:	Texas Transportation Institute
Test Report Number:	401761-ATG1
Model Name/Number:	ATG-SMB
Barrier Rating:	K4
Brief Description:	Shallow mount bollards; array of three

The above vehicle barrier system will be placed on the DOS list of certified equipment that is available for use by architects and planners. To retain this certification in good standing, the installation and use of this barrier must match the tested design. Your product still has to compete with other bidding manufacturers who are certified with the same classification. We cannot guarantee that your product will be chosen by architects that design the facilities.

Thank you for your interest and endeavors in protecting our personnel and facilities overseas.

Sincerely yours,

Charles Brandeis  
Division Chief  
Physical Security Division  
Bureau of Diplomatic Security